


## IAPMO RESEARCH AND TESTING, INC.

5001 E. Philadelphia Street, Ontario, CA 91761-2816 • (909) 472-4100 • Fax (909) 472-4244 • [www.iapmort.org](http://www.iapmort.org)



### CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body which tests and inspects samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

The most updated information on this Certificate of Listing is available online at [pld.iapmo.org](http://pld.iapmo.org)

Effective Date: June 2015 Void After: June 2016

Product: Prefabricated Septic Tanks File No. 4622

Issued To: ROTH GLOBAL PLASTICS  
P.O. BOX 245  
SYRACUSE, NY 13211

Identification: Each tank shall be marked with the following information: 1) manufacturer's name or trademark; 2) model number; 3) working liquid volume in gallons and liters; 4) date (i.e., month and year), date code, or identifier traceable to the date of manufacture; 5) maximum design load and maximum burial depth for which the tank is designed in feet and meters; 6) volume of the chamber(s) as a function of depth in gallons per inch and liters per centimeter (this can be affixed to the tank exterior or provided in the manufacturer's product literature); 7) inlet and outlet; 8) type of tank (e.g., H, T, S, P, ES or EP); and 7) statement "above-ground installation not permitted" or "AGINP" (where applicable). For a concrete tank, a marking shall indicate whether it is suitable for sulphate or non-sulphate soils, i.e. "SUL" or "NON-SUL". Markings shall be permanent, legible, and visible. Acceptable means of applying permanent markings shall include permanently-affixed metal plates, etching, mechanical stamping, stamping with a permanent (non-water-soluble) ink, and molding in. Markings shall be located on the top of the tank near the access opening or at the end of the tank near the inlet. The product shall also bear the cUPC® certification mark adjacent to product markings.

Characteristics: Prefabricated septic tanks made of concrete, fiber-reinforced polyester (FRP), thermoplastic, or steel. To be installed in accordance with the manufacturer's instructions and the latest edition of the Uniform Plumbing Code.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

Products are in compliance with the following code(s):

Uniform Plumbing Code (UPC®)  
National Plumbing Code of Canada  
International Plumbing Code (IPC®)

Products are in compliance with the following standard(s):

IAPMO/ANSI Z1000-2013 and CSA B66-2012

MODELS:

Septech™

RMT-750, RMT-1000E, RMT-1060, RMT-1250, RMT-1500



**Print Certificate**